



TOWN OF WESTMINSTER

11 South Street
WESTMINSTER, MASSACHUSETTS 01473
(978) 874-7409 • Fax (978) 874-7460

BOARD OF HEALTH

RECEIVED
2016 MAY 12 PM 4:23
TOWN OF WESTMINSTER

AGENDA FOR MAY 18, 2016

B.O.H. MEETING

HELD IN THE WESTMINSTER TOWN HALL
11 SOUTH ST., WESTMINSTER, MA 01473

Responsibility/Date

Open Meeting.

Sign Minutes and vouchers.

Agent Update:

Board Members Concerns:

24 Miles Ave./Robertson, John Deline. Local
Upgrade/Variance Requests:

1. 310 CMR 15.405 (1)(h). Offset to groundwater: 4 feet required, 3 feet proposed.
2. 310 CMR 15.405 (1)(j). Offset to groundwater from invert elevations of the septic tank and pump chamber: 1 foot required, 2 inches proposed. (The plan uses Monolithic Tanks)
3. Local Reg. 245-3 Size of leaching area. 125% of Title 5 design required, Title 5 design size proposed.

62 Oakmont Ave., Paul Grasewicz. Continued from
May 4 BOH Meeting.